

PRE-BID ADDENDUM NO. 2
THE TOWN OF SMITHFIELD, VIRGINIA
RENOVATIONS-REPAIRS
TOWN STORAGE BUILDING
IFB # 01-2015

June 22, 2015

GENERAL INFORMATION

1. The Request for Bid is modified by this Addendum.
2. All firms must acknowledge receipt of this Addendum in their submission.
3. The following revisions, additions, and clarifications are hereby made part of the IFB solicitation IFB 01-2015.

CLARIFICATIONS:

- A. The date to receive proposals remains the same and shall **be Thursday, June 25, 2015 at 2:00 pm.**
- B. Delete the originally specified Metal Roof entirely. Replace with a TPO Single Ply roof system, Minimum 60 mil, white, thermoplastic membrane, mechanically fastened. Provide all end, eve, edge, fascia and other flashing systems to ensure a watertight roofing system.

END OF ADDENDUM